

SALES SPECIFICATION SHEET
OLC GR 12X30

Acid Washed Coconut Granular Activated Carbon

Test	Specification		Calgon Carbon Test Method
	Min	Max	
IODINE NUMBER, mg/g	900	-	ASTM D4607
ASH, wt%	-	2	ASTM D2866
MOISTURE (AS PACKAGED), wt%	-	8	ASTM D2867
pH (EXTRACTABLE) (ASTM)	6	7.5	ASTM D3838
12 US MESH [1.70 mm], wt%	-	5	ASTM D2862
< 30 US MESH [0.600 mm] (PAN), wt%	-	5	ASTM D2862

Typical Properties:

Only products bearing the NSF Mark are Certified to NSF/ANSI 61 - Drinking Water System Components - Health Effects standard. Certified Products will bear the NSF Mark on packing or documentation shipped with the product.

THIS PRODUCT IS NOT INCLUDED IN THE SCOPE OF CCC'S QUALITY SYSTEM CERTIFIED TO ISO 9001.
NOTE: CCC'S Quality System elements are applied whenever possible.

Calgon Carbon Corporation's activated carbon products are continuously being improved and changes may have taken place since this publication went to press. (2143-29/01/2015)